

Certificate



Intertek


for European Product Safety

Reference No. 1221810

Socket outlets

Type designation	L528, L973
Certificate holder	ELKO AS Eyvind Lyches vei 10 1338 Sandvika Norway
The product complies with the standard(s)	IEC 60884-1:2002 and A1 SS 428 08 34:2004
Date of expiry	24 October 2017

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Bo Berglöf	Date	24 October 2012 Page 1 of 4

**Intertek**
Appendix

Reference No. 1221810

Technical data

Type designation	L528
Rated voltage (V)	250 V~
Rated current (A)	16 A
IP-Class	21
Standard sheet	III
Brand name:	ELKO
Product information	Catalogue ID: RS1014 PT. Socket-outlet for fixed installation. Thermoplastic, flush mounting, 1 gang with/without lid, with shutters and screw terminals. With RS and Plus design.

Type designation	L528
Rated voltage (V)	250 V~
Rated current (A)	16 A
IP-Class	21
Standard sheet	III
Brand name:	ELKO
Product information	Catalogue ID: S1014 PT. Socket-outlet for fixed installation. Thermoplastic, flush mounting, 1 gang without frame, with shutters and screw terminals. With RS and Plus design.

Type designation	L528
Rated voltage (V)	250 V~
Rated current (A)	16 A
IP-Class	21, 44
Standard sheet	III
Brand name:	ELKO
Product information	Catalogue ID: 1054 IF PT. Socket-outlet for fixed installation. Thermoplastic, flush mounting, 1 gang with lid, with/without key lock, with shutters and screw terminals. IP21, IP44 with splash-screen type L479, with RS and Plus design.

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

**Intertek**
Appendix*Reference No. 1221810*

<i>Type designation</i>	L973
<i>Rated voltage (V)</i>	250 V~
<i>Rated current (A)</i>	16 A
<i>IP-Class</i>	21
<i>Standard sheet</i>	III
<i>Brand name:</i>	ELKO
<i>Product information</i>	Catalogue ID: H1014 PT. Socket-outlet for fixed installation. Thermoplastic, flush mounting, 1 gang, with shutters and screwless terminals. ELCONNECT L957. With RS and Plus design.

<i>Type designation</i>	L973
<i>Rated voltage (V)</i>	250 V~
<i>Rated current (A)</i>	16 A
<i>IP-Class</i>	21
<i>Standard sheet</i>	III
<i>Brand name:</i>	ELKO
<i>Product information</i>	Catalogue ID: HS1014 PT. Socket-outlet for fixed installation. Thermoplastic, flush mounting, 1 gang, without frame, with shutters and screwless terminals. ELCONNECT L957. With RS and Plus design.

<i>Manufacturing site(s)</i>	Elko AS Sporpind Industriområde 3340 Åmot Norway
------------------------------	---

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1221810

The certificate applies for countries that have sanctioned the use of plugs/outlets according to subject standard sheet and component standard.

This certificate is based on a certificate with ref. No. P12215817 dated 31 August 2012, issued by Nemko according to the Nordic Certification Service Agreement.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Bo Berglöf *Date* 24 October 2012

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.