

# Certificate



Intertek

for European Product Safety

Reference No. 1225504

## Socket outlets

<i>Type designation</i>	L701, L801
<i>Certificate holder</i>	<b>Elko A/S</b> Eyvind Lyches vei 10 NO-1338 Sandvika NORWAY
<i>The product complies with the standard(s)</i>	SS 428 08 34:2004 IEC 60884-1:2002 and A1
<i>Date of expiry</i>	27 December 2017

Additional information in Appendix.

*Certification Body* Intertek Semko AB, Product Certification

*Place* Kista - Stockholm

*Signed*

  
\_\_\_\_\_  
Paul Klemets

*Date* 27 December 2012  
Page 1 of 2



**Intertek  
Appendix**

Reference No. 1225504

*Technical data*

Type designation	L701, L801
Rated voltage (V)	250
Rated current (A)	16
IP-Class	20
Standard sheet	I
Catalogue ID	H 1050 PT
Brand name:	ELKO
Product information	Socket outlet for fixed installation, thermoplastic, surface mounting, 2 gang, with shutters and screw less terminals. Enclosure complies with IP21.

Type designation	L801
Rated voltage (V)	250
Rated current (A)	16
IP-Class	21
Standard sheet	I
Catalogue ID	H 1051 PT
Brand name:	ELKO
Product information	Socket outlet for fixed installation, thermoplastic, flush mounting, 2 gang, with shutters and screw and screw less terminals.

*Manufacturing site(s)* Elko AS  
Sporpind Industriområde  
NO-3341 Åmot, NORWAY

This certificate is based on a certificate with ref. No. P12216358 dated 30 November 2012, issued by Nemko AS according to the Nordic Certification Service Agreement.

*Certification Body* Intertek Semko AB, Product Certification *Place* Kista - Stockholm

*Signed*   
Paul Klemets *Date* 27 December 2012

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*