

# Certificate



for European Product Safety

Reference No. 1011379

## Socket-outlet


Type designation	1088 PT
Certificate holder	<b>ELKO A/S</b> Eyvind Lyches vei 10 NO-1301 Sandvika NORWAY
The product complies with the standard(s)	SS 428 08 34:2004 IEC 60884-1:2002 and A1
Date of expiry	22 February 2015

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

  
Bo Berglöf

Date 22 February 2010  
Page 1 of 2

**Intertek  
Appendix**

Reference No. 1011379

*Technical data*

Type designation	1088 PT
Rated voltage (V)	250
Rated current (A)	16/2.5
Standard sheet	III and XVla
Brand name:	ELKO
Product information	6 euro + 2 schuko socket outlet for fixed installation. For surface mounting with shutters, screw terminals.

Manufacturing site(s)	Schneider Electric, Loxel Fabrika Bukultu 7 Riga, LV-1005 LATVIA
-----------------------	---

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate is based on a certificate with ref. No. P10211898 dated 19 February 2010, issued by Nemko AS according to the Nordic Certification Service Agreement.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed	 Bo Berglöf	Date	22 February 2010
--------	--	------	------------------

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*